



County of Riverside  
**DEPARTMENT OF ENVIRONMENTAL HEALTH**

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

KEITH JONES, DIRECTOR

Date: January 30, 2019

System No. 3301564

Riverside County Parks Dept.  
Re: Hurkey Creek Park  
Attn: Dayna Whitaker  
4600 Crestmore Road  
Jurupa Valley, CA 92509

Enclosed is Citation No. 05\_63\_19C\_004 issued to Hurkey Creek Park.

Any person who is aggrieved by a Citation issued by the Riverside County LPA may file a petition with the State Water Resources Control Board (State Water Board) for reconsideration of the Citation. Petitions must be received by the State Water Board within 30 calendar days of the issuance of the Citation. The date of issuance is the date when the Riverside County LPA mails or serves a copy of the Citation, whichever occurs first. If the 30<sup>th</sup> day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m. Information regarding filing petitions may be found at:

[http://www.waterboards.ca.gov/drinking\\_water/programs/petitions/index.shtml](http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml)

If you have any questions regarding this matter, please contact me at (760) 863-7570.

Sincerely,

Jackie Jones  
Environmental Health Specialist

RIVERSIDE COUNTY  
DEPARTMENT OF ENVIRONMENTAL HEALTH

**Name of Public Water System:** Hurkey Creek Park

**Water System No:** 3301564

**Attention:** Riverside County Parks Department

4600 Crestmore Road

Riverside, CA 92506

**Issued:** January 30, 2019

**CITATION FOR NONCOMPLIANCE WITH  
CALIFORNIA HEALTH AND SAFETY CODE, SECTION 116555(a) (1)  
AND  
CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64423**

**TOTAL COLIFORM MONITORING VIOLATION**

**Fourth Quarter 2018**

The California Health and Safety Code (hereinafter "CHSC"), Section 116650 authorizes the Riverside County Department of Environmental Health (hereinafter "Riverside County"), acting by and through its primacy delegation from the State Water Resources Control Board (State Water Board), to issue a citation to a public water system when Riverside County determines that the public water system has violated or is violating the California Safe Drinking

1 Water Act (hereinafter "California SDWA"), (CHSC, Division 104, Part 12,  
2 Chapter 4, commencing with Section 116270), or any regulation, standard,  
3 permit, or order issued or adopted thereunder.

4  
5 Riverside County acting by and through its primacy delegation from the State  
6 Water Board, hereby issues Citation No. 05\_63\_19C\_004 (hereinafter  
7 "Citation"), pursuant to Section 116650 of the CHSC to Hurkey Creek Park  
8 (hereinafter "Hurkey Creek"), for violation of CHSC, Section 116555(a)(1) and  
9 California Code of Regulations (hereinafter "CCR"), Title 22, Section 64423.

#### 10 11 **STATEMENT OF FACTS**

12 Hurkey Creek Park is classified as a Transient public water system with 130  
13 campground spaces serving up to 80,000 visitors annually. There is also a  
14 group camping area with five loops that can accommodate up to 100 people  
15 per loop.

16  
17 CHSC, Section 116555(a)(1) requires all public water systems to comply with  
18 primary drinking water standards as defined in CHSC, Section 116275(c).  
19 Primary drinking water standards include maximum levels of contaminants  
20 and the monitoring and reporting requirements as specified in regulations  
21 adopted by the State Water Board that pertain to maximum contaminant  
22 levels.

23  
24 CCR, Title 22, Section 64421(a)(2) states that each water supplier shall  
25 collect routine, repeat and replacement samples as required in Sections  
26 64423, 64424 and 64425. Section 64423 states that a water supplier shall  
27 collect routine bacteriological water samples based on the known population  
28 served or the total number of service connections, whichever results in the

1 greater number of samples. As per 64423 (a) (3), Hurkey Creek must collect  
2 a minimum of one bacteriological sample per quarter when serving 1000 or  
3 fewer persons a month. As per 64423 (a) (4), the minimum number of  
4 bacteriological samples when Hurkey Creek serves more than 1000 persons  
5 during any month shall be based on the known population served as shown  
6 in Table 64423-A attached hereto in Attachment 3.

7 As of the date of this Citation, Riverside County received no routine results for  
8 routine bacteriological sample(s) taken during the fourth quarter of 2018.

### 10 DETERMINATION

11  
12 In accordance with CCR, Title 22, Section 64423, Hurkey Creek Park was  
13 required to collect one bacteriological sample during the fourth quarter of  
14 2018. Therefore, Riverside County has determined that Hurkey Creek has  
15 failed to comply with drinking water standards pursuant to CHSC, Section  
16 116555(a) (1) and CCR, Title 22, Section 64423 during the fourth quarter of  
17 2018.

### 19 DIRECTIVES

20 Hurkey Creek is hereby directed to take the following actions:

- 21
- 22 1. On or before **March 1, 2019**, notify all persons served by Hurkey Creek  
23 of the violation of CCR, Title 22, Section 64423, in conformance with  
24 Sections 64463.4(b) and (c) and 64465. Attachment 1: Notification  
25 Template shall be used to fulfill this Directive, unless otherwise  
26 approved by Riverside County.

27  
28 The notification shall be completed in accordance with the following:

- Posting of the Public Notification in conspicuous places within the area served by the water system. The notice shall remain posted for a minimum of seven (7) consecutive days and;
- By one of the following secondary methods to reach persons not likely to be reached by mail or direct delivery;
  - By publication in a local newspaper, by delivery to community organizations or by posting in conspicuous public places served by the water system or on the internet. If the water system opts to issue the notice via internet website, the public notice shall remain posted for a minimum of seven (7) consecutive days.

2. Complete the attached Compliance Certification Form (Attachment 2). Submit it together with a copy of the public notification required by Directive 1 to Riverside County on or before **March 15, 2019**.

All submittals required by this Citation shall be submitted to the following address or electronically to [jaiones@rivco.org](mailto:jaiones@rivco.org).

Department of Environmental Health  
Attn: Jackie Jones  
47-950 Arabia St, Ste A  
Indio, CA 92201

Riverside County Department of Environmental Health reserves the right to make modifications to this Citation as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

1 Nothing in this Citation relieves Hurkey Creek of its obligation to meet the  
2 requirements of the California SDWA (CHSC, Division 104, Part 12, Chapter  
3 4, commencing with Section 116270), or any regulation, standard, permit or  
4 order issued or adopted thereunder.

#### 5 6 **PARTIES BOUND**

7 This Citation shall apply to and be binding upon Hurkey Creek Park, its  
8 owners, shareholders, officers, directors, agents, employees, contractors,  
9 successors, and assignees.

#### 10 11 **SEVERABILITY**

12 The directives of this Citation are severable, and Hurkey Creek Park shall  
13 comply with each and every provision thereof notwithstanding the  
14 effectiveness of any provision.

#### 15 16 **FURTHER ENFORCEMENT ACTION**

17 The California SDWA authorizes Riverside County Department of  
18 Environmental Health, pursuant to authority delegated by the State Water  
19 Board, to: issue a citation or order with assessment of administrative penalties  
20 to a public water system for violation or continued violation of the  
21 requirements of the California SDWA or any regulation, permit, standard,  
22 citation, or order issued or adopted thereunder including, but not limited to,  
23 failure to correct a violation identified in a citation or compliance order.  
24 Pursuant to its delegated authority, the California SDWA also authorizes  
25 Riverside County Department of Environmental Health to take action to  
26 suspend or revoke a permit that has been issued to a public water system if  
27 the public water system has violated applicable law or regulations or has failed  
28 to comply with a citation or order of the Riverside County Department of

1 Environmental Health, and to petition the superior court to take various  
2 enforcement measures against a public water system that has failed to  
3 comply with a citation or order of the Riverside County Department of  
4 Environmental Health. The Riverside County Department of Environmental  
5 Health does not waive any further enforcement action by issuance of this  
6 Citation.

7  
8  
9 Jackie Jones

10 Jackie Jones, REHS

11 Environmental Health Specialist

1-30-2019

12 Date

13  
14 Attachments:

- 15 1. Notification Template  
16 2. Compliance Certification Form  
17 3. Table 64423-A

18  
19  
20 Certified Mail No. 7007 3020 0001 6549 0026



## NOTIFICATION TEMPLATE

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

Este informe contiene información muy importante sobre su agua potable.  
Por favor hable con alguien que lo pueda traducir.

**Bacteriological Monitoring Requirements**

**Not Met for Hurkey Creek Park During the Fourth Quarter of 2018  
(October to December)**

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did to correct the situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the fourth quarter of 2018, we did not meet all monitoring requirements for coliform bacteria and therefore cannot be sure of the quality of our drinking water during that time.

**What should I do?**

- **You do not need to boil your water or take other corrective actions.**
- The table below lists the contaminant we did not properly test for during the fourth quarter of 2018 (October to December), how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were taken
Bacteria	One sample per quarter	0	Fourth quarter 2018 (October to December)	January 18, 2019

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.



What happened? What is being done?

The Fourth Quarter bacteria sample was not taken from the distribution system. It was overlooked.

We have since taken the required samples, as described in the last column of the table above. The samples showed we are meeting drinking water standards.

For more information, please contact:

Ranger Anthony Miller at (951) 529-5620

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

### **Secondary Notification Requirements**

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Hurkey Creek Park in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.

State Water System ID: Hurkey Creek Park. Date distributed:

## COMPLIANCE CERTIFICATION

Citation Number: 05\_63\_19C\_004

Name of Water System: Hurkey Creek Park

System Number: 3301564

### Certification

I certify that the users of the water supplied by this water system were notified of the bacteriological monitoring violation of California Code of Regulations, Title 22, Section 64424(a), (b) and (d) for the compliance period of Fourth Quarter of 2018 and the required actions listed below were completed.

Required Action	Date Completed
(Citation Directive 1) Public Notification Method(s) Used:	

\_\_\_\_\_  
Signature of Water System Representative

\_\_\_\_\_  
Date

**Attach a copy of the public notice distributed to the water system's customers**

<b>THIS FORM MUST BE COMPLETED AND RETURNED TO Riverside County Department of Environmental Health, NO LATER THAN March 15, 2019.</b>
---

**Disclosure:** Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than \$25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment.

*NOTE: This publication is meant to be an aid to the staff of the State Board's Division of Drinking Water and cannot be relied upon by the regulated community as the State of California's representation of the law. The published codes are the only official representation of the law. Refer to the published codes—in this case, 17 CCR and 22 CCR—whenever specific citations are required. Statutes related to the State Board's drinking water-related activities are in the Health & Safety Code, the Water Code, and other codes.*

**Table 64423-A  
Minimum Number of Routine Total Coliform Samples**

<i>Monthly Population Served</i>	<i>Service Connections</i>	<i>Minimum Number of Samples</i>
25 to 1000	15 to 400	1 per month
1,001 to 2,500	401 to 890	2 per month
2,501 to 3,300	891 to 1,180	3 per month
3,301 to 4,100	1,181 to 1,460	4 per month
4,101 to 4,900	1,461 to 1,750	5 per month
4,901 to 5,800	1,751 to 2,100	6 per month
5,801 to 6,700	2,101 to 2,400	7 per month
6,701 to 7,600	2,401 to 2,700	2 per week
7,601 to 12,900	2,701 to 4,600	3 per week
12,901 to 17,200	4,601 to 6,100	4 per week
17,201 to 21,500	6,101 to 7,700	5 per week
21,501 to 25,000	7,701 to 8,900	6 per week
25,001 to 33,000	8,901 to 11,800	8 per week
33,001 to 41,000	11,801 to 14,600	10 per week
41,001 to 50,000	14,601 to 17,900	12 per week
50,001 to 59,000	17,901 to 21,100	15 per week
59,001 to 70,000	21,101 to 25,000	18 per week
70,001 to 83,000	25,001 to 29,600	20 per week
83,001 to 96,000	29,601 to 34,300	23 per week
96,001 to 130,000	34,301 to 46,400	25 per week
130,001 to 220,000	46,401 to 78,600	30 per week
220,001 to 320,000	78,601 to 114,300	38 per week
320,001 to 450,000	114,301 to 160,700	50 per week
450,001 to 600,000	160,701 to 214,300	55 per week
600,001 to 780,000	214,301 to 278,600	60 per week
780,001 to 970,000	278,601 to 346,400	70 per week
970,001 to 1,230,000	346,401 to 439,300	75 per week
1,230,001 to 1,520,000	439,301 to 542,900	85 per week
1,520,001 to 1,850,000	542,901 to 660,700	90 per week
1,850,001 to 2,270,000	660,701 to 810,700	98 per week
2,270,001 to 3,020,000	810,701 to 1,078,600	105 per week
3,020,001 to 3,960,000	1,078,601 to 1,414,300	110 per week
3,960,001 or more	1,414,301 or more	120 per week